


FIRE RESCUE



Jim Budzinski
FIRE CHIEF

Fire Alarm Pull Station Notification Sign Specifications

**Local Alarm Only
In Case of Fire
Call 911**

EXAMPLE ABOVE NOT TO SCALE

- 1) The letters shall be red on a white background
- 2) The minimum height of each letter shall be 1/2 inch.
- 3) The minimum stroke width of each letter shall be 1/8 inch.
- 4) The sign shall be durable waterproof and fade resistant.
- 5) The sign shall be located no higher than 4 inches directly above the fire alarm pull station.
- 6) The sign shall be a minimum of 2 ½ inches in height and a minimum 5 inches in width.

Code Reference:

2007 Florida Fire Prevention Code,
NFPA 101, Section 31.3.4.3.5.1 & Section 4.6.1.3

"Committed to Excellence...Always."

3.4.09

TAMARAC.ORG

6000 Hiatus Road | Tamarac, Florida 33321-6416 | P: 954.597.3800 | F: 954.597.3810

EQUAL OPPORTUNITY EMPLOYER